

TAMIL NADU ELECTRICITY BOARD

From
Er. P. Murugesan, B.E.,
Executive Engineer,
Transformer Erection,
Madurai – 625 007.

To
M/s. Asia Power Electrical,
No.31/1, New Ennore High Road,
Thiruvottiyur,
Chennai – 600 019.

Lr.No.EE/TE/MDU/SDM/D.No. /09 dt. 11.3.2009.

Sir,

Sub: Performance of 16 MVA, 110/33-11 KV T&R make Sl.No.01263
Power transformer – Repaired by Asia Power Electrical/Chennai –
Supplied against the P.O.No.1101/D/248/03 dt. 12.8.2003.

Ref: Your Lr.No. dt. 10th March 2009.

With reference to above, it is certified that the above Power transformer
has been repaired by Asia Power Electrical/Chennai and commissioned on 5.4.2007
at 110/11 KV Kannanoor sub-station has been working with a load of 12.38 MVA
satisfactorily.

Yours faithfully,

[Handwritten Signature]
11/3/2009

**EXECUTIVE ENGINEER
TRANSFORMER ERECTION/MADURAI**

**EXECUTIVE ENGINEER
TRANSFORMER ERECTION
Tamilnadu Electricity Board
MADURAI-625007**