

:: TAMIL NADU TRANSMISSION CORPORATION LTD. ::

From

Er. S. SHANMUGAM, B.E.,  
Chief Engineer/Transmission,  
6<sup>th</sup> Floor, NPKRR Maaligai,  
144, Anna Salai, Chennai – 600 002.

To

M/s. Asia Power Electrical,  
No. 31/1, New Ennore high Road,  
Thiruvottyur, Chennai – 600 019.  
Fax no. 044 – 2573 4767.  
E mail : [asiapower@rediffmail.com](mailto:asiapower@rediffmail.com)

Lr.No.CE/TR/SE/TR-II/ET/A1/F.Contract No.369/D. 466 /'15, Dt. 17.12.2015.

Dear Sir/s,

SUB : Contract No. 369, dated 26.05.2012 - Repairing and reconditioning of 110KV class sick Power Transformers – 'EMCO' make 16MVA 110/33-11KV Power Transformer failed at Eppodumvendran SS – Inspection completed and allotted to Kattumannarkoil SS towards Failure replacement – Regarding.

REF : AEE/Inspection/MM-I's Inspection report dated 16.12.2015.

\* \* \*

The test results of the routine tests conducted on the repaired unit of 'EMCO' make 16MVA 110/33-11KV Power Transformer failed at Eppodumvendran SS, repaired against subject Repair Contract, are found to be in order and hence accepted. The above unit is allotted to the following substation:

<u>Unit Sl.No.</u>	<u>Allotted to</u>	<u>GCC</u>	<u>Towards</u>
EMCO make (Sl. No. HT 1458/11941)	Kattumannarkoil SS/ Cuddalore EDC	Trichy	Replacement of the failed 16MVA unit.

Please note that the above unit and all its connected accessories may be transported at the earliest after getting approval from the concerned SE/GCC. The date of receipt of last item connected with the transformer will be taken as the date of receipt of transformer for estimate preparation.

This approval does not absolve you of your responsibilities to fulfill other terms and conditions of the contract. Receipt of this letter may please be acknowledged.

Yours faithfully,

  
for CHIEF ENGINEER/TRANSMISSION

Copy to CE/TR. Projects-II/Trichy and CE/Distn./Villupuram region.

Copy to SE/GCC/Trichy. The above 16MVA 110/33-11KV Power Transformer is allotted to Kattumannarkoil SS towards failure replacement. The unit may be arranged to be commissioned early.

Copy to SE/Cuddalore EDC. Transaction of the allotted unit may be regularized early.

Copy to EE/Transformer Erection/Chennai

Copy to EE/TRB/Ambattur- for information & action with regard to failed 16MVA unit.