

:: TAMIL NADU TRANSMISSION CORPORATION LTD. ::

From

Er. N. Krishnasami, B.E.,  
Chief Engineer/Transmission,  
6<sup>th</sup> Floor, NPKRR Maaligai,  
144, Anna Salai, Chennai – 600 002.

To

M/s. Asia Power Electrical,  
No. 19, Ennore High Road,  
Tiruvottiyur,  
Chennai – 600 019.

Lr.No.CE/TR/SE/TR-II/ET/A1/F. Contract No.369/D. 304 /'14, Dt. 1.11.'14.

Dear Sir/s,

SUB : Contract No. 369, dated 26.05.2012 - Repairing and reconditioning of 110KV class sick Power Transformers – 'Voltamp' make 50MVA 110/33KV Power Transformer failed at Perungudi SS –Inspection completed and to be allotted to Avadi SS towards enhancement - regarding.

REF : AEE/Inspection/MM-I's Inspection report dated 18.10.2014.

\*\*\*

The test results of the routine tests conducted on the repaired unit of 'Voltamp' make 50MVA 110/33KV Power Transformer failed at Perungudi SS, repaired against subject Repair Contract, are found to be in order and hence accepted. The above unit is allotted to the following substation:

<u>Unit Sl.No.</u>	<u>Allotted to</u>	<u>GCC</u>	<u>Towards</u>
Voltamp make (Sl. No. JN 8615/3)	Avadi SS/ CEDC(West)	Chennai	Enhancement

Please note that the above unit and all its connected accessories may be transported at the earliest after getting approval from the concerned SE/GCC. The date of receipt of last item connected with the transformer will be taken as the date of receipt of transformer for estimate preparation.

This approval does not absolve you of your responsibilities to fulfill other terms and conditions of the contract. Receipt of this letter may please be acknowledged.

Yours faithfully,

  
For CHIEF ENGINEER/TRANSMISSION

Copy to CE/TR. Projects-I/Chennai and CE/Distrn./North region.  
Copy to SE/GCC-I/Chennai. The unit may be arranged to be commissioned early.  
Copy to SE/~~CEDC/WEST~~ -Transaction of the allotted unit may be regularized early.  
Copy to EE/Transformer Erection/Chennai.

2/7